

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 4485-1361:101 Page 1 of 1

CATEGORY: Opening Protection (Firestopping)

LISTEE: Thermal Ceramics, P.O. Box 923, Augusta, GA 30903  
Contact: Vicki Floyd (706) 796-4482 FAX (706) 560-4056

DESIGN: Type FireMaster® DuctWrap and FireMaster® DuctWrap+ for use in through-penetration steel air duct. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as duct wrap for use in through-penetration firestop system up to 3 hours when installed in accordance with UL Fire Resistance Directory. Approved system: UL System No. C-AJ-7004. Intended for through-penetration steel air duct only.

NOTE: For grease duct applications, please consult the authority having jurisdiction for approval.

\*Rev. 06-05-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**